



TAMIL NADU FIRE AND RESCUE SERVICES LICENCE
(Under section 13 of the Tamil Nadu Fire Service Act 1985 and
Tamil Nadu Fire Service Rule 1990 - Appendix-III)

Licence No: 11626/RFL/NMSB/2025
Dated: 25/06/2025

District Office,
Fire and Rescue Service,
Cuddalore District.

RENEWAL OF FIRE LICENSE

Ref: Letter no:302462 from the Krishnasamy College of
Engineering & Technology, Dated: 23/06/2025

The Fire License is hereby renewed under section 13 of the Tamil Nadu Fire and Rescue Service Act 1985 for In the name of Krishnasamy College of Engineering & Technology, Nellikuppam High Road, S.Kumarappuram, Cuddalore, Cuddalore, 607109. Consisting of G+3 floors with the Height of 13.97 Meters and total built-up area in 22912.00 Sqm within the jurisdiction of Cuddalore based on the inspection was done by the Assistant District Officer Cuddalore on 24/6/2025. Subject to the condition noted thereon and such other conditions as may be prescribed. This license is valid for **THREE YEARS** from 25/06/2025 to 24/06/2028 and should be renewed on 24/06/2028.

CONDITIONS

1. All firefighting equipment should always be kept in good working condition at all times and it should be as per the NBC 2016 part -IV maintained well and working in good condition. The trained personnel should always be available to operate the systems in case of any emergency.
2. Fire extinguishers should be installed and maintained as per IS 2190:2010
3. All Staff should be trained in preliminary firefighting as per G.O.No:713 Home (Police-17), Dated: 17.08.2005 with Fire and Rescue Services Department.
4. Mock drill should be periodically conducted.
5. Any addition and/or alteration of a permanent or temporary structure should be intimated to the Fire and Rescue Services Department.
6. Fire order / contingency plan / evacuation plan should be prepared and displayed in each floor at prominent places and Do's & Don'ts boards should be displayed.
7. Emergency fire exit, staircases and doors should not be obstructed.
8. Good housekeeping should be maintained and dumping of waste materials and debris should be avoided.
9. All the electrical equipment, fitting, accessories and Wiring system should be as per the Indian Standard Code of Practice for Fire Safety of Building (General) Electrical Installation should be followed.
10. All buildings (A to D blocks) Hose Reel System should be provided with in Three months.
11. If there is any deviation from the Govt. Rule and Act the License issued will stand cancelled.

District Officer,

Signature valid

Sd/- District Officer, Cuddalore
Central Region - District Officer,
Home Department
Date: 25-Jun-2025 14:37:37



Fire and Rescue Services

Cuddalore District

To:

Krishnasamy College of Engineering & Technology,

S.Kumarappuram Village,

Cuddalore Taluk,

Cuddalore District

KCET - CUDDALORE-607109				
Incoming Tapal No: 773				
O.P	R.P	Courier	In Person	e-mail
26 JUN 2025				
9				
CHAIRMAN	ED	PRINCIPAL	VP	AO

Signature valid

Signed by: District Officer Cuddalore,
Central Region - District Officer,
Home Department
Date: 25-Jun-2025 14:37:37