



KRISHNASAMY

College of ENGINEERING & TECHNOLOGY

Approved by AICTE & Affiliated to Anna University

Anand Nagar, Nellikuppam Main Road, S. Kumarapuram, Cuddalore - 607 109, Tamil Nadu.

☎ (04142) 285 601 - 604

🌐 www.kcet.in

✉ info@kcet.in

Consultancy - **EICL Limited** Dated: 26.04.2019



Date: 26th April'19

To

The HOD,
Krishnaswamy college of engineering,
Cuddalore.

Subject: Requisition for Compressive strength test

Sir/ Madam,

We have five sample of concrete blocks (M20- 2Nos, M25- 3Nos) and we request you to conduct compressive strength test as per Indian standards of given samples and provide the standard report as earlier as possible.

Thanking You,

Sincerely,

S.Suresh

Process department

EICL LIMITED

Plot No. A/5 - 2, SIPCOT Industrial Estate,
Cuddalore Chidambaram Road, Cuddalore - 607 005.

CIN : U 26939 KL 1963 PLC 002039

Registered Office : TC-99/34 Velli, Thiruvananthapuram - 695 021, Kerala, India

www.eicl.in

Inward letter

DUPLICATE

KRISHNASAMY COLLEGE OF ENGINEERING & TECHNOLOGY
NELLIKUPPAM MAIN ROAD - S.KUMARAPURAM CUDDALORE - 607109
Phone:04142285601 Fax:04142290394

RECEIPT

Receipt No: FC18/06718 Date : 26/04/2019

Name : EICL LIMITED Class : CIVIL

Particulars	Amount
TESTING CUBES	600.00
Total	600.00

Amount in Words : Rupees Six Hundred Only

Bill receipt for testing



KRISHNASAMY

College of ENGINEERING & TECHNOLOGY

Approved by AICTE & Affiliated to Anna University

Anand Nagar, Nellikuppam Main Road, S. Kumarapuram, Cuddalore - 607 109, Tamil Nadu.

☎ (04142) 285 601 - 604

🌐 www.kcet.in

✉ info@kcet.in



KRISHNASAMY COLLEGE OF ENGINEERING & TECHNOLOGY CUDDALORE - 607 109

CIVIL ENGINEERING DEPARTMENT

Receipt No: FC18/06718 dt 26/04/2019

To: M/S EICL LIMITED,
Plot no.A/5-2, SIPCOT Industrial Estate,
Cuddalore Chidambaram Road,
Cuddalore-607 005.

Date: 29.04.2019

Sub: Testing of Concrete Cubes - Reg.

S. No	Mark on the Specimen	Grade of Concrete	Date of Casting	Date of Testing	Weight of Cube (kg)	Ultimate Load (kN)	Compressive Strength (N/mm ²)
1	26.03.2019	M25	26.03.2019	26.04.2019	8.235	171	7.6
2	26.03.2019	M25	26.03.2019	26.04.2019	7.405	130	5.77
3	26.03.2019	M25	26.03.2019	26.04.2019	8.320	163	7.24
4	25.03.2019	M20	25.03.2019	26.04.2019	8.295	235	10.44
5	25.03.2019	M20	25.03.2019	26.04.2019	8.045	194	8.62

(Sample not drawn by KCET)

S. S. S.
24/4/19
Faculty In-charge
Head of the Department
Civil Engg.



Received
[Signature]
9600323700

[Signature]
29/4/19
Principal
PRINCIPAL
Krishnasamy College of
Engineering & Technology
Benji Kumarapuram
Cuddalore - 607 109

Testing report for the given sample