



# KRISHNASAMY

## College of ENGINEERING & TECHNOLOGY

Approved by AICTE & Affiliated to Anna University

Anand Nagar, Nellikuppam Main Road, S. Kumarapuram, Cuddalore - 607 109, Tamil Nadu.

☎ (04142) 285 601 - 604

🌐 www.kcet.in

✉ info@kcet.in

Consultancy – **Jeevan Ready Mix Concrete** Dated: 06.09.2021

From,

Jeevan Ready mix,  
Maradhan village,  
Cuddalore.

To,

The Civil Department HOD,  
KCET College,  
Nellikuppam,  
Cuddalore.

Respected Sir,

As we need crushing strength of coarse aggregate  
(12mm and 20mm) kindly test and give report.

Thanking you.

Sir/Madam,

To collect Rs 300 for  
Crushing strength of  
coarse aggregate.

D. 06/09/21  
(HOD/CIVIL).

Yours Faithfully,  
Jeevan Ready mix.

### Inward Letter

KRISHNASAMY COLLEGE OF ENGINEERING & TECHNOLOGY  
ANAND NAGAR NELLIKUPPAM MAIN ROAD S. KUMARAPURAM CUDDALORE 607109  
PHONE: 04142285601 FAX: 04142280004

#### RECEIPT

Receipt No: RC21/00036 Date: 06/09/2021

Name: JEEVAN READY MIX CUDDALORE Class:

Particulars	Amount
TESTING CUBES	300.00
Total	300.00

Amount in Words: Rupees Three Hundred Only



Cashier

Bill receipt for testing



# KRISHNASAMY

## College of ENGINEERING & TECHNOLOGY

Approved by AICTE & Affiliated to Anna University

Anand Nagar, Nellikuppam Main Road, S. Kumarapuram, Cuddalore - 607 109, Tamil Nadu.

☎ (04142) 285 601 - 604

🌐 www.kcet.in

✉ info@kcet.in



### KRISHNASAMY COLLEGE OF ENGINEERING & TECHNOLOGY CUDDALORE - 607 109

#### CIVIL ENGINEERING DEPARTMENT

Receipt No: FC21/00036 dt 06.09.2021


To: M/s. Jeevan Ready Mix Concrete  
Home Guards Nagar,  
Behind Krishnasamy Engineering College,  
Marudhadu village,  
Cuddalore.

Date: 15.09.2021


Sub: Crushing test of coarse aggregate - Reg.

S. No	Size of aggregate	Weight of empty mould (kg)	Weight of mould with aggregate (kg)	Weight of aggregate (kg)	Date of Testing	Weight of fraction passing through (kg)	Crushing value	Remarks
1	12mm	10.17	12.9	2.73	09.09.2021	0.158	5.7%	As per IS: 456-2000, the test results are satisfactory
2	20mm	10.17	12.69	2.5	09.09.2021	0.110	4.4%	

(The sample was not drawn by KCET)

  
Faculty In-charge



  
Principal  
PRINCIPAL  
Krishnasamy College of  
Engineering & Technology  
Senji Kumarapuram  
Cuddalore - 607 109.

**Testing report for the given sample**